

RECEIVED

JUL 10 2017

ENVIRONMENT & CONSERVATION
COOKEVILLE FIELD OFFICE

7-10-17

July 10, 2017

To: Wm. Oakley Hall at TDEC

From: Tommy Buford at Baxter, TN WWTP, Permit Number TN0021121

Re: Written Overflow Notification

A 1.90" rainfall event in about two hours and flash flooding in the Baxter area caused heavy infiltration in Baxter's collection system. As a result, Baxter had one wet weather overflow at the wet-well to our plant pump station that is situated about 50' from Mine Lick Creek. This pump station is the last pump station in our collection system and it pumps all of the town's wastewater to the WWTP.

The overflow started at approximately 7:00pm on Thursday, July 6, 2017 and continued until approximately 10:00pm on Thursday, July 6. The duration of the overflow was approximately three hours. Approximately 5,000 gallons overflowed.

During the overflow bales of wheat straw were in place at the wet-well in order to prevent solids from reaching Mine Lick Creek. All debris will be raked up and disposed of and agricultural lime will be applied to prevent possible odors at the overflow site.

If you have questions or need additional information please contact me at 931-858-3348. Thank you.

Tommy Buford
7-10-17